



Silver State Labs-Reno  
1135 Financial Blvd  
Reno, NV 89502  
(775) 857-2400 FAX: (888) 398-7002  
www.ssalabs.com

September 26, 2019  
Workorder **19090950**

Jay Flakus  
CITY OF YERINGTON  
102 South Main Street  
Yerington, NV 89447

Project: 35 Whiteface Ln

Dear Jay Flakus:

It is the policy of Silver State Analytical Laboratory - Reno to strictly adhere to a comprehensive Quality Assurance Plan that ensures the data presented in this report are both accurate and precise. Silver State Analytical Laboratory - Reno maintains accreditation in the State of Nevada (NV-00015) and the State of California (ELAP 2990).

The data presented in this report was obtained from the analysis of samples received under a chain of custody. Unless otherwise noted below, samples were received in good condition, properly preserved and within the hold time for the requested analyses. Any anomalies associated with the analysis of the samples have been flagged with an appropriate explanation in the Analysis Report section of the Laboratory Report.

Sincerely,

Carly Wood  
Laboratory Director  
1135 Financial Blvd  
Reno, NV 89502



Silver State Labs-Reno  
1135 Financial Blvd  
Reno, NV 89502  
(775) 857-2400 FAX: (888) 398-7002  
www.ssalabs.com

# Analytical Report

Workorder#: 19090950  
Date Reported: 9/26/2019

**Client:** CITY OF YERINGTON

**Sampled By** Jay Flakus

**Project Name:** 35 Whiteface Ln

**PO #:**

**Laboratory Accreditation Number** NV015/CA2990

<b>Laboratory ID</b>	<b>Client Sample ID</b>	<b>Date/Time Sampled</b>	<b>Date Received</b>
19090950-01	35 Whiteface Ln.	09/18/2019 8:10	9/18/2019

Parameter	Method	Result	Units	MCL	Analyst	Date/Time Analyzed	Data Flag
Coliform, Total	SM 9223 B	Absent	P/A	0	AM	09/18/2019 16:54	
Escherichia Coli	SM 9223 B	Absent	P/A	0	AM	09/18/2019 16:54	

**Laboratory Accreditation Number** NV015/CA2990

<b>Laboratory ID</b>	<b>Client Sample ID</b>	<b>Date/Time Sampled</b>	<b>Date Received</b>
19090950-02	102 S. Main St.	09/18/2019 8:28	9/18/2019

Parameter	Method	Result	Units	MCL	Analyst	Date/Time Analyzed	Data Flag
Coliform, Total	SM 9223 B	Absent	P/A	0	AM	09/18/2019 16:54	
Escherichia Coli	SM 9223 B	Absent	P/A	0	AM	09/18/2019 16:54	

**Laboratory Accreditation Number** NV015/CA2990

<b>Laboratory ID</b>	<b>Client Sample ID</b>	<b>Date/Time Sampled</b>	<b>Date Received</b>
19090950-03	422 Silverstar Ct.	09/18/2019 9:14	9/18/2019

Parameter	Method	Result	Units	MCL	Analyst	Date/Time Analyzed	Data Flag
Coliform, Total	SM 9223 B	Absent	P/A	0	AM	09/18/2019 16:54	
Escherichia Coli	SM 9223 B	Absent	P/A	0	AM	09/18/2019 16:54	

Original



**SilverState**  
Analytical Laboratories

Sierra Environmental Monitoring  
EnviroTech

3620 E. SUNSET RD., SUITE 100, LAS VEGAS, NV 89121  
Phone (702) 873-4478 Fax: (702) 873-7967 (EPA#: NV000930, CA28885)  
1135 FINANCIAL BOULEVARD, RENO, NV 89502  
Phone (775) 857-2400 Fax: (888) 398-7002 (EPA#: NV00015, CA2526)

CHAIN-OF-CUSTOMER-RECORD  
Page 1 of 1

ssalabs.com sen-analytical.com envirotechonline.com

**Report Results To:**

Report Attention: Jay Flakus, Public Works Director Project Number:  
 Company: City of Yerington Nevada - Public Works  
 Mailing Address: 102 S Main Street  
 City, State, Zip: Yerington, NV 89447  
 Phone: 775-302-1155 Email / Fax: jayf@yerington.net

**Send Invoice To:**

Invoice Attention: Jay Flakus PO# OPEN Quote #  
 Company: City of Yerington Nevada - Public Works  
 Mailing Address: 102 S Main Street  
 City, State, Zip: Yerington, NV 89447  
 Phone: 775-302-1155 Email / Fax: jayf@yerington.net

Sampled by: JAY FLAKUS Signature: [Signature]

I attest to the validity and authenticity of the sample. I am aware that tampering with or intentionally mislabeling the sample location, date or time is considered fraud and may be grounds for legal action.

Standard:  Standard TAT 7-10 Business Days. Note that some tests vary.  
 Rush: Same Day:  3 Day:  Other (specify):  
 1 Day:  4 Day:  Rush results will be issued after 4:00 p.m.  
 2 Day:  5 Day:

NOTE: A Rush Surcharge is applied for rush samples

Other Pertinent Information / Special Instructions: MONTHLY COLIFORM SAMPLING

Date Sampled	Time Sampled	Sample Identification	SSAL - SEM Lab No.	Comp. Grab	Matrix	Preservative**	Number / Type of Containers ***	TOTAL COLIFORM
9/18/19	0810	35 Whiteface Ln.		G	DW	5	1(P)	X
	0828	102 S. Main St		G	DW	5	1(P)	X
	0914	422 Silverstar Ct.		G	DW	5	1(P)	X

Print Name: Jay Flakus

Signature: [Signature]

Relinquished By: [Signature] Date: 9/18/19 Time: 1128

Received By: [Signature] Date: 9/18/19 Time: 1400

Relinquished By: [Signature] Date: 9/18/19 Time: 1128

Received By: [Signature] Date: 9/18/19 Time: 1400

Authorized By: [Signature] Date: 9/18/19 Time: 1128

Company: City of Yerington, NV

Authorization is required to process samples. This obligates your organization for service fees. SSAL Standard T & C's or other written agreement applies. If collections or legal services are required to recover said fees, your organization will be responsible for all fees and costs in addition to service fees.

Matrix\* DW-Drinking Water, WW-Waste Water, GW-Ground Water, SW-Surface Water, SS-Soil, S-Solid, OT-Other  
 Preservative\*\* 1-H<sub>2</sub>SO<sub>4</sub>, 2-HNO<sub>3</sub>, 3-HCl, 4-NaOH, 5-Na<sub>2</sub>O<sub>2</sub>, 6=None, 7=Other

City of Yerington NV - SDM  
 2019 Compliance Monitoring  
 19025

NOTE: Surcharges apply to Level II, III and IV reports

QC Level Report:  II  III  IV

Send Results Via: Mail:  Email:  Fax:   
 Send Invoice Via: Mail:  Email:  Fax:

Field Measurements: On-Site pH: Chlorine: Temperature: Other:



Silver State Labs-Reno  
1135 Financial Blvd  
Reno, NV 89502  
(775) 857-2400 FAX: (888) 398-7002  
www.ssalabs.com

## Definitions & Qualifiers

WO#: 19090950

Date: 9/26/2019

### Definitions:

LCS: Laboratory Control Sample; prepared by adding a known mass of target analytes to a specified amount of de-ionized water and prepared with the batch of samples, used to calculate Accuracy (%REC).

LCSD: LCS Duplicate; used to calculate both Accuracy (%REC) and Precision (%RPD)

MBLK: Method Blank; a sample of similar matrix that is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedure, and in which no target analytes or interferences are present at concentrations that impact the analytical results for sample analyses.

MS: Matrix Spike; prepared by adding a known mass of target analytes to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available, used to calculate Accuracy (%REC)

MSD: Matrix Spike Duplicate; used to calculate both Accuracy (%REC) and Precision (%RPD)

RPD: Relative Percent Difference; comparison between sample and duplicate and/or MS and MSD.

PQL: Practical Quantitation Limit; the limit to which data is quantitated for reporting.

MDL: Method Detection Limit; the limit to which the instrument can reliably detect.

MCL: Maximum Contaminant Level; value set according to EPA guidelines.

### Qualifiers:

\* - Analyte exceeds Safe Drinking Water Act MCL, does not meet drinking water standards.

C - Analyte value below Safe Drinking Water Act MCL, does not meet drinking water standards.

B - Analyte found above the PQL in associated method blank.

G - Calibration blank analyte detected above PQL.

H - Sample analyzed beyond holding time for this parameter.

J - Estimated Value; Analyte found between MDL and PQL limits.

L - Sample concentration is at least 5 times greater than spike contribution. Spike recovery criteria do not apply.

R - RPD between sample and duplicate sample outside the RPD acceptance limits.

S - Batch MS and/or MSD were outside acceptance limits, batch LCS was acceptable.

W - Sample temperature when received was out of limit as specified by method.